
Wallplates and accessories | Designer | Claro, and Satin Colors,



Product family features

- Can be used in conjunction with the following dimmer(s), switch(es), sensor(s), and accessories: Maestro®, Maestro IR®, Maestro Wireless®, Caséta® Wireless, Pico® wireless, Diva®, Skylark Contour® and Skylark® controls, and Claro® and Satin Colors® accessories
- All Lutron wallplates are screwless, seamless, and have no visible hardware; the front plate securely snaps into the alignment adapter plate
- · Full line of wiring devices in Designer style opening
- Blank inserts available for Gloss (DV-BI-) and Satin Colors (SC-BI-)

Ganging and derating

- Designer wallplates use standard ganging
- Requires fins to be removed from dimmers for proper spacing ("Fins Broken" ganging)
- May require derating (i.e., reduction of dimmer capacity due to fin removal), see Derating Tables

Available finishes

Use **BOLD** color code in model number (Example: SC-1-**PL**) Gloss finishes



*Stainless Steel finish wallplates include black plastic trim/adapter, visible from side. Match with separate Black (BL) or Midnight (MN) controls and accessories.

UTRON

Receptacles



- Tamper resistant receptacles include tamper resistant shutter mechanism (shutters are white)
- · Wallplate sold separately

Receptacles

15A 125V	CAR-15- XX 1
15A 125V	SCR-15- XX ²
20A 125V	SCR-20- XX ²

Tamper-resistant receptacles

CARS-15-TR-XX1
SCRS-15-TR-XX2
SCRS-20-TR-XX2

USB receptacles

i.	١,	
Ő.	İ	1
-	•	

- Includes two USB ports
- Ports are rated for a minimum of 10,000 insertions and removals
- Wallplate sold separately


Tamper-resistant USB receptacles

15A 125V	CAR-15-UBTR-XX1
15A 125V	SCR-15-UBTR-XX2

Important notes


- Receptacles and plugs for dimming use are UL listed for use with all Lutron wallbox dimmers included in this catalog.
- If there is only one electrical feed to the receptacle, then the duplex DFDU must be used.
- If the hot and dimmed hot feeds to the split duplex HFDU are supplied from different circuits or splitwired with separate switch-legs, a means to simultaneously disconnect these circuits must be provided at the panel board where they originate (NEC 210.7(C) 2002 Edition).
 A 2-pole circuit breaker or two single-pole circuit breakers with an approved handle tie can be used to accomplish this simultaneous disconnect.
 Feed-through dimming panels, which are those without breakers, are recommended when using the HFDU.


XX¹: Gloss color codes XX²: Satin Colors_® codes





Telephone jack wiring, 8-conductor






*For split circuit wiring, break off tab on brass side only

Wiring diagram #31

GFCI receptacle wiring



Wiring diagram #32

Single-pole wiring of 3-way, 3-wire control

